


NOTE: MATERIALS AND FABRICATION IN ACCORDANCE WITH MH-1 MANHOLE.
 SIZE OF AIR RELEASE VALVE AS SPECIFIED.
 WHERE NOTED ON PLANS, USE STANDARD METER BOX AS CHAMBER AND
 SUPPORT WITH TWO (2) COURSES OF BRICK.

CONNECT PIPE OR COPPER
 TUBING TO OUTLET AND
 EXTEND UP 12". USE FITTINGS
 AS REQUIRED. PROVIDE
 SCREENED, DOWNWARD-
 FACING ELBOW AND PIPE.

AIR RELEASE VALVE
 AS DETAILED IN
 SPECIFICATIONS.

BALL VALVE
 TAPPED FORCE
 MAIN (USE D.I.
 SLEEVE)

ASTM D-448 NO. 68 STONE
 TO TOP OF MAIN



ENGINEERING
 DEPARTMENT
 100 EAST MAIN STREET
 CHRISTIANSBURG, VA 24075
 (540) 382-6120 PHONE
 (540) 381-7238 FAX
 engineering@christiansburg.org

PRECAST CHAMBER FOR
 AIR RELEASE VALVE
 (SEWER)

DATE: 01 NOV 2004
 SCALE: N.T.S.
 DETAIL NO.
 AR-3