



NOTES:

1. IF THE PIPE IS LAID IN AN EXCAVATED TRENCH, THEN THE SIDE WALLS MAY CONFORM TO THE TRENCH SHAPE (I.E. THE TRENCH MAY BECOME THE CRADLE FORM).
2. COMPRESSIVE STRENGTH OF CONCRETE MATERIAL FOR CRADLE SHALL BE 4000 PSI.
3. PIPE SHALL BE REINFORCED CONCRETE PIPE WITH RUBBER GASKETS IN ACCORDANCE WITH VDOT ROAD AND BRIDGE STANDARDS AND SPECIFICATIONS, AASHTO M170 (PIPE), AND ASTM C443 (GASKET).
4. CONCRETE CRADLE SHALL BEGIN AT RISER OR INLET END OF PIPE AND SHALL EXTEND THE FULL LENGTH OF THE PIPE



ENGINEERING
DEPARTMENT
100 EAST MAIN STREET
CHRISTIANSBURG, VA 24073
(540) 382-6120 PHONE
(540) 381-7238 FAX
engineering@christiansburg.org

CONCRETE CRADLE

DATE: 01 NOV 2004
SCALE: N.T.S.
DETAIL NO.
CC-1