



- NOTES:**
1. FIRE HYDRANT MANUFACTURER AND MODEL AS APPROVED BY TOWN.
  2. LOCK JOINT SYSTEMS AS APPROVED BY THE TOWN..
  3. MAY BE USED IN LIEU OF RODS AND CLAMPS. WEEP HOLES AND ACCOMPANYING
  4. DRYWELLS WILL ONLY BE LOCATED WHERE BOTH THE WEEP HOLE AND THE DRYWELL AND ABOVE THE SEASONAL HIGH GROUNDWATER TABLE AND ARE NOT SUBJECT TO SURFACE WATER FLOODING OR PONDING.
  5. THE TOWN WILL FIELD LOCATE EACH FIRE HYDRANT THAT MAY BE AFFECTED BY THE SEASONAL HIGH GROUNDWATER OR SURFACE WATER. EACH WEEP HOLE SUBJECT TO CONTAMINATION WILL BE SEALED, THE HYDRANT MARKED AND HYDRANT LOCATION MAPPED FOR MANUAL DEWATERING.



ENGINEERING  
DEPARTMENT  
100 EAST MAIN STREET  
CHRISTIANSBURG, VA 24073  
(540) 382-6120 PHONE  
(540) 381-7238 FAX  
engineering@christiansburg.org

FIRE HYDRANT  
INSTALLATION

DATE: 11 AUG 2014  
SCALE: N.T.S.  
DETAIL NO.  
FH-I