



**NOTES:**

1. ROD GATE VALVES TO TEES OR PROVIDE RESTRAINER GLANDS
2. CONTRACTOR MAY UTILIZE 2" TAPPING SLEEVE AND VALVE TO CONNECT TO 8" MAIN IN LIEU OF TEE AND 2" VALVE
3. A PLACARD SHOWING THE DESIGN DISCHARGE PRESSURE AND THE ANTICIPATED RANGE OF INLET PRESSURE SHOULD BE INSTALLED INSIDE THE VAULT.



ENGINEERING  
DEPARTMENT  
100 EAST MAIN STREET  
CHRISTIANSBURG, VA 24073  
(540) 382-6120 PHONE  
(540) 381-7238 FAX  
[engineering@christiansburg.org](mailto:engineering@christiansburg.org)

8-INCH PRESSURE REDUCING  
VALVE ASSEMBLY WITH  
2-INCH BYPASS

DATE: 11 AUG 2014  
SCALE: N.T.S.  
DETAIL NO.  
RV-2