



NOTES:

1. CENTERLINE OF METER CONNECTIONS NOT MORE THAN 24" OR LESS THAN 20" FROM TOP OF BOX.
2. FOR $\frac{3}{4}$ " AND 1" METERS: TRAFFIC BEARING INSTALLATIONS SHALL USE A CONCRETE METER BOX WITH CAST IRON FRAME AND COVER. FOR NON-TRAFFIC BEARING INSTALLATIONS, PLASTIC CORRUGATED METER BOX SHALL BE USED. COLOR SHALL BE WHITE AND A PLASTIC FRAME AND COVER MAY BE USED.
3. MINIMUM DEPTH TO SERVICE LINE IS 36".
4. DO NOT INSTALL BRICKS OVER WATER LINE.
5. METER INSTALLED BY TOWN AT OWNER'S EXPENSE.



ENGINEERING
DEPARTMENT
100 EAST MAIN STREET
CHRISTIANSBURG, VA 24073
(540) 382-6120 PHONE
(540) 381-7238 FAX
engineering@christiansburg.org

**WATER METER INSTALLATION
(FOR 1" TO 2" METERS)**

DATE: 15 JUL 2021
SCALE: N.T.S.
DETAIL NO.
SC-3